

DECLARATION OF CONFORMITY

EDT14 and EDT24 Series

This product is manufactured at the premises of West Control Solutions, The Hyde Business Park, Brighton, East Sussex, BN2 4JU, England, UK

This declaration of conformity is issued under the sole responsibility of the manufacturer.

The objects of this declaration are the products identified using the model numbers derived from the tables listed below.

The objects of this declaration are in conformity with the following European Union harmonisation legislation:

2014/30/EU Electromagnetic Compatibility

2014/35/EU Low Voltage Directive

2011/65/EU Restriction of Hazardous Substances in Electrical and Electronic Equipment

The assessment of conformity has been made using the standards route to compliance. The standards this product is compliant with are listed below: -

EN 61326-1:2013 Electrical equipment for measurement, control and laboratory use — EMC Requirements — Part 1: General Requirements


This product has been evaluated as Class A equipment suitable for operation in Industrial Locations against this standard.

WARNING

This is a Class A product. In a domestic environment this product may cause radio interference in which case the user may be required to take adequate measures.

EN 61010-1:2010, Safety requirements for electrical equipment for measurement, control and laboratory use.

This declaration is made for and on behalf of Fortive by Stephan Sommer, who has been designated as the responsible person for the purpose of the regulations.

Signature: 
(S. Sommer)

Date of Issue: 20107116

Order Code	EDT14	x	x	-	NTC	-	XXX
Number of input sensors							
One		1					
two		2					
Number of outputs							
1 x 8 amp relay (EDT141x only)			1				
2 x 8 amp relay (EDT141x only)	(2nd o/p for evap' temp')		2				
3 x 8 amp relay (EDT1423 only)			3				
Sensor type							
NTC only					NTC		
Power supply input							
230vac							230
12v ac/dc							12
24v ac/dc							24

Order Code	EDT24	xx	-	xxx	-	x	-	xxx	-	xxx
Number of input and outputs										
1x NTC input, 1 x relay output		11								
1x NTC input, 2x relay output		12								
2x NTC input, 3x relay output (2nd o/p for evap' temp')		23								
Power supply input										
230VAC				230						
110VAC				110						
12V AC/DC				12						
24V AC/DC				24						
9 - 30VDC / 7-24VAC				SM						
Compressor Output Relay										
8A output						R				
16A output (not on EDT2423)						P				
Options										
Not fitted								(blank)		(blank)
Real time clock (only available with 8A relay devices)								RTC		
Modbus RTU										RS